



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ  
Dilovası OSB Mahallesi Fırat Caddesi No: 18  
Dilovası, Kocaeli / TÜRKİYE  
www.efectis.com

## DECLARATION OF TEST RESULTS

No: ERA – 2400-0021

The related reaction to fire tests were carried out for the product as described below at Efectis Era Avrasya Test Laboratory on 11 October 2024. Classification of reaction to fire has been carried out in accordance the standard:

**EN 13501-1:2018**

**“ALUMINIUM SNAP FRAME”**

Fire behaviour		Smoke production		Flaming droplets
B	-	s	1	, d 0

**Flammability Classification\***

**Hardly inflammable**

\*Turkey's regulation on fire protection 2009, Appendix-2/Ç the table of flammability classification of construction materials in accordance with EN 13501-1

Placed on the market by: ORES TANITIM SİSTEMLERİ SAN. VE TİC. LTD. ŞTİ.  
Seyrantepe Mah. Gülizar Sk. B Blok No: 16/A Kağıthane, İstanbul / TÜRKİYE

Manufactured by: ORES TANITIM SİSTEMLERİ SAN. VE TİC. LTD. ŞTİ.  
Sakarya 1. OSB 2. Cad. No:12 Arifiye, Sakarya / TÜRKİYE

*e-signed*

Ali BAYRAKTAR  
Laboratory Manager  
17.10.2024

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report No: ERA-24-267.

